

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2021				Day : Sunday				Date : 21.02.21			
Probable Maximum Demand : 8700 MW				Yesterday = 9290 ft				Probable Maximum Generation : 13467 MW			
Water Level of Kaptai Lake at 06:00 AM				Today = 9278 ft				Rule Curve = 9420 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.02.21 (Yesterday)		21.02.21 (Today)		20.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation	Probable start-up date	
(A) Plants in operation:											
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	110	110	110		
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	220	220	0	220		
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	12	12	12	12		
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint. 7/3/2021
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Under maint.
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	343	338	412	412		
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	87	33	100	100	177	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	70	0	0	265	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	7	64	100	100		
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	285	250	300	300		
15	Meghnaghat 100 MW(HEL)	HFO (QRPP)	12x8.9	100	100	0	18	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	64	80	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	40	59	60	60		
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	0	100	102		
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	22	22		
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x167+7x8.73	80	80	53	56	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	17	25	25		
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	33	33		
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	115	149	149		
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50		
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	277	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	45	137	149	149		
31	Keraniganj 300 MW PP (APRI)	HSD (IPP)	25x6.14	300	300	0	0	100	300		
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	17	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	88	104	104		
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	144	144	144		
	Spectra Solar Plant Ltd.	Solar				11	0	30	0		
Dhaka Zone Total			6171	5972	1854	2456	3309	3751	527	1090	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0		
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	3	42	46	46		
45	Sikalbaha 105 MW PP (Baraka Siks)	HFO (IPP)	6x18.415	105	105	0	0	50	100		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	215	306	300	300		
49	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	100	100		
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	40	100	100	100		
51	Dohazari Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	85	85		
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			15	31	20	30		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	24	102	102		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	53	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	70	100	100	100		
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116		
Chattogram Zone Total			2442	2382	436	797	1325	1360	715	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26	19	Gas Shortage
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	188	194	225	225		
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	270	270	285	285		
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	275	260	300	300		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	20	40	40	35	Gas Shortage
65	Ashuganj 185MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50	
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	90	81	90	90		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	68	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	20	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14.4+1x15+1x15+1x15+1x15	200	200	0	0	0	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	26	113	113		
**	Impoport (Tripura)	India		160	160	78	108	135	147		
	Bhairon 54.5 MW	HFO (IPP)				17	22	0	0		
Cumilla Zone Total			3040	2980	1096	1169	1674	1936	840	0	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	120	139	165	160	63	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	56	72	80	80		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	32	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0		
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	17	20	22	22		
Mymensingh Zone Total			717	709	427	485	656	599	63	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.02.21 (Yesterday)		21.02.21 (Today)		20.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	50	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0		Contract Expired on 14/02/2021		
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
92	Hobiganj	11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66	Under maint.		
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	118	155	155	155	175	Gas Shortage		
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	75	75				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231	Gas Shortage		
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0		Contract Expired on 04/01/2020		
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	5	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	341	341				
102	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	426	400	400				
		Bibiyana South 400 MW	Gas (PDB)				0	0	0	0				
		Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0		On Test		
Sylhet Zone Total						2033	1988	1027	1074	1122	1122	406	66	
103	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	420	410	410	410				
105	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
106	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	12	60	60				
107	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna	115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	49	115	115				
109	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40				
111	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	17	90	90	90				
112	Machumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		823	846	645	838				
Khulna Zone Total						2288	2284	1260	1407	1535	2014	0	0	
113	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110				
114	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	23	26	26				
115	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194	Under maint.		
116	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	60	75	95	95				
117	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	380	420	620	620				
118	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total						1826	1826	458	550	1001	1001	0	194	
119	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50				
121	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
123	Ammura	50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	12	12	12				
124	Chapainawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	104	104				
125	Katakali	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
126	Katakali	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
127	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
128	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
129	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage		
130	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	179	182	220	220				
131	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	345	360	400	400				
132	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	21	22	22				
133	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0		Contract Expired on 12/11/2020		
134	Ullapara	11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
135	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
136	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	35	100	113	113				
137	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113				
Rajshahi Zone Total						2193	2183	662	949	1297	1421	601	0	
138	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
139	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	225	150	150	150				
140	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0	20	Under Overhauling		
141	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	107	113	113	113				
142	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara	Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total						685	605	337	263	271	263	170	20	
Sub-total: Plants in operation						21395	20929	7557.0	9150	12190	13467	3322	1550	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						7340	8887	11839	13080					
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0			
Gross Total						21395	20929	7557	9150	12190	13467	3322	1550	
(C) Actual data of 20.02.21 (Yesterday) Saturday :														
01.	Max. Demand (Generation end)			: 9150.00 MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):									
02.	Max. Demand (Sub-station end)			: 8887.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)			: 9150.00 MW, at = 19:00 hrs	Dhaka	3027	3027	0	Mymensingh	787	787	0		
04.	Minimum Generation (Generation end)			: 5984.00 MW, at = 5:00 hrs	Chattogram	981	981	0	Sylhet	346	346	0		
05.	Day-peak Generation (Generation end)			: 7557.00 MW, at = 12:00 hrs	Khulna	1076	1076	0	Barishal	241	241	0		
06.	Evening-peak Generation (Generation end)			: 9150.00 MW, at = 19:00 hrs	Rajshahi	984	984	0	Rangpur	685	685	0		
07.	Evening Peak Load-shed (Sub-station end)			: 0.00 MW, at = 19:00 hrs	Cumilla	760	760	0	Total	8887	8887	0		
08.	Actual Minimum Generation up to 8:00 hrs.			: 5905.00 MW, at = 7:00 hrs	13.	Fuel cost :	(a) Gas = 114391346 Taka	(c) Coal = 70063251 Taka						
09.	Generation shortfall at evening peak due to :						(b) Oil = 216941858 Taka	Total = 401396455 Taka						
	a)	Gas limitation	: 2992 MW											
	c)	Coal supply Limitation	: 170 MW											
	b)	Low water level in Kaptai lake	: 160 MW											
	c)	Plants under shut down/ maintenance	: 1550 MW											
10.	Total Energy (Generation + India Import)			: 180.78 MCKWh	14.	Maximum Temperature in Dhaka was :			26.1° C					
	By Gas = 105.705 MCKWh			By Hydro = 37.204 MCKWh	15.	Export through East-West interconnections :								
	By Coal = 14.986 MCKWh			By Hydro = 1.688 MCKWh		At evening peak-hour			: 57 MW, at 19:00 hrs					
	By Solar = 0.360 MCKWh					Maximum			: 27 MW, at 20:00 hrs					
						Energy			: 0.001 MCKWh					
11.	Total Gas Supplied			: 856.20 MCMCFD										
(D) Forecast of 21.02.21 (Today) Sunday :														
01.	Maximum Demand			: 8700 MW (Generation end)	04.	Maximum Load-shed			: 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation			: 13467 MW (Generation end)	05.	Total Generation			: 171.89 MCKWh					
03.	Maximum Shortage			: -4767 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :			31.0° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation