

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021		Day : Friday				Date : 05.03.21						
Probable Maximum Demand :		9600 MW		Yesterday = 90.92 ft		Today = 90.73 ft		Probable Maximum Generation : 14581 MW				
Water Level of Kaptai Lake at 06:00 AM								Rule Curve = 92.36 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.03.21 (Yesterday)		05.03.21 (Today)		04.03.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.	
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	180	300	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	12	12	12	12			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint.	
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	400	450	450	50		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	367	357	412	412			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	80	100	100	100			
14	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	270	260	300	300			
15	Meghnaghat 100 MW(IEU)	HFO (QRPP)	12x8.9	100	100	1	64	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	30	80	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	61	87	100	100			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	32	72	100	102			
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	49	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	52	52			
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	70	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	82	149	149			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	25	50	50			
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	230	265	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	118	122	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	44	55	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	5	72	144	144			
	Spectra Solar Plant Ltd.	Solar				29	0	30	0			
Dhaka Zone Total			6171	5972	2466	2988	3832	4054	385	1160		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	46	50	50			
45	Sikalbaha 105 MW PP (Baraka Siks)	HFO (IPP)	6x18.415	105	105	0	0	50	100			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	10	100	100			
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	305	287	300	300			
49	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	100	100	100	100			
50	Juldah 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	70	100	100			
51	Dohazari - Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	85	85			
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	16	16			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	21	30	30			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	44	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	39	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Accor)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	35	116	116			
Chattogram Zone Total			2442	2382	702	947	1433	1458	565	180		
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	3	10	10	42	Gas Shortage	
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	161	199	225	225			
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	260	260	300	300			
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	265	300	300	300			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas shortage	
65	Ashuganj 185MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	94	92	94			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	114	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	16	33	33			
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	25	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	21	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14.4+1x15+1x15+1x15	200	200	0	0	0	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	72	113	113			
**	Impoport (Tripura)	India		160	160	116	146	135	147			
	Bhairab 54.5 MW	HFO (IPP)				56	56	55	55			
Cumilla Zone Total			3040	2980	949	1339	1687	1951	886	0		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	85	105	150	150			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	17	17			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	46	82	82			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	39	76	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	192	193	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.03.21 (Yesterday)		05.03.21 (Today)		04.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	48	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	34	36	36	36		30	Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	162	162	162	162	168		Gas Shortage	
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	83	83	83				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	136	163	137	137		68	Under maint.	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	7	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	310	341	341				
102	Bibiyana	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	360	330	350	350				
		Bibiyana South 400 MW	Gas (PDB)				342	320	370	400				
		Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total					2033	1988	1708	1710	1793	1823	168	98		
103	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	190	180	240	240	230		Gas Shortage	
105	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
106	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	6	60	60				
107	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	17	66	115	115				
109	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40				
111	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	53	105	105	105				
112	Machumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		717	836	852	827				
Khulna Zone Total					2288	2284	977	1233	1587	1848	230	0		
113	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	110	110				
114	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	26	26	27				
115	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
116	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	44	75	95	95				
117	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	410	620	620				
118	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
Bhola Nutan Biddut BD LTD							70	70	70	70				
Barishal Zone Total					1826	1826	545	629	1071	1072	0	194		
119	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50				
121	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
123	Ammura	50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	12	12	12				
124	Chapanawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	104	104				
125	Katakali	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
126	Katakali	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
127	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	34				
128	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage	
129	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	170	150	170	170				
131	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	408	354	400	400				
132	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22				
133	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
134	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
135	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
136	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113				
137	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113				
Rajshahi Zone Total					2193	2183	866	981	1297	1421	601	0		
138	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	124	112	105	105			Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
139	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150	150				
140	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		20	Under Overhauling	
141	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	113	107	113	113				
142	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara	Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	392	369	376	368	85	20		
Sub-total: Plants in operation					21395	20929	9014.0	10640	13714	14581	2920	1652		
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							8662	10224	13177	14011				
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance					0	0	0	0	0	0				
Gross Total					21395	20929	9014	10640	13714	14581	2920	1652		
(C) Actual data of 04.03.21 (Yesterday) Thursday :														
01.	Max. Demand (Generation end)	: 10640.00 MW, at = 19:00 hrs					12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand (Sub-station end)	: 10224.00 MW, at = 19:00 hrs					Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	: 10640.00 MW, at = 19:00 hrs					Dhaka	3643	3643	0	Mymensingh	879	879	0
04.	Minimum Generation (Generation end)	: 6990.00 MW, at = 5:00 hrs					Chattogram	1139	1139	0	Sylhet	369	369	0
05.	Day-peak Generation (Generation end)	: 9014.00 MW, at = 12:00 hrs					Khulna	1257	1257	0	Barishal	278	278	0
06.	Evening-peak Generation (Generation end)	: 10640.00 MW, at = 19:00 hrs					Rajshahi	1065	1065	0	Rangpur	680	680	0
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs					Cumilla	914	914	0				
08.	Actual Minimum Generation up to 8:00 hrs.	: 7363.00 MW, at = 7:00 hrs									Total	10224	10224	0
09.	Generation shortfall at evening peak due to :						13.	Fuel cost :	(a) Gas = 118935030 Taka	(c) Coal = 84941881 Taka				
	a) Gas limitation	: 2675 MW						(b) Oil = 370877728 Taka	Total = 54754639 Taka					
	d) Coal supply Limitation	: 85 MW					14.	Maximum Temperature in Dhaka was :	32.4° C					
	b) Low water level in Kaptai lake	: 160 MW					15.	Export through East-West interconnections :						
	c) Plants under shut down/ maintenance	: 1652 MW						At evening peak-hour	: -192 MW, at 19:00 hrs					
10.	Total Energy (Generation + India Import)	: 213.08 MKWh						Maximum	: -215 MW, at 20:00 hrs					
	By Gas = 118.351 MKWh							Energy	: 0.788 MKWh					
	By Coal = 17.533 MKWh													
	By Solar = 0.710 MKWh													
11.	Total Gas Supplied	: 926.94 MMCFD												
(D) Forecast of 05.03.21 (Today) Friday :														
01.	Maximum Demand	: 9600 MW (Generation end)					04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	: 14581 MW (Generation end)					05.	Total Generation	: 192.25 MKWh					
03.	Maximum Shortage	: -4981 MW (Generation end)					06.	Probable Max. Temperature in Dhaka :	32.4° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at