

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021		Day : Sunday				Date : 14.03.21						
Probable Maximum Demand : 11800 MW		Yesterday = 89.34 ft		Today = 89.19 ft		Probable Maximum Generation : 15521 MW						
Water Level of Kaptai Lake at 06:00 AM		Rule Curve = 90.92 ft.										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.03.21 (Yesterday)		14.03.21 (Today)		13.03.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.	
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190			
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	300	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	99	106	108	108			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	342	354	300	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Dirt in fuel gas	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirt in fuel gas	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	180	140	115	115	70	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	219	222	220	300		113	ST Under maint.
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	7 12x8.9	100	100	8	7	100	100			
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	245	230	300	300			
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	0	0	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	15	64	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	35	55	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	36	10	85	86			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	7	100	100			
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	0	22	22			
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	56	56	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52			
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	24	25	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149			
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	16	0	50	50			
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	14	95	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	113	113	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	0	55	55			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	24	34	90	90			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	144	144			
	Spectra Solar Plant Ltd.	Solar				27	0	30	0			
Dhaka Zone Total			6171	5972	2075	2120	3702	4063	1057	578		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	47	50	50	50			
45	Sikalbaha 105 MW PP (Baraka Siks)	HFO (IPP)	6x18.415	105	105	0	0	50	100			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	120	120	120			
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	210	204	225	225			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	198	142	300	300			
49	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	100	100			
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	0	50	100	100			
51	Dohazari Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102			
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	19	20	20			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	10	10	20			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116			
Chattogram Zone Total			2442	2382	762	995	1799	1834	160	180		
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	120	120	100	120			
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	26	25	26	19		Gas Shortage
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	183	183	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	290	300	300			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	30	360	360			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	56	55	55			
65	Ashuganj 185MW PP (APSCL United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	86	85	90	90			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	110	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33			
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+4x1.715+1x1.026	200	200	0	0	0	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	8	113	113			
**	Impoport (Tripura)	India		160	160	124	132	151	168			
	Bhairab 54.5 MW	HFO (IPP)				0	0	0	0			
Cumilla Zone Total			3040	2980	1327	1090	1871	2159	679	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	123	108	160	160	94		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	0	22	22			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	50	50			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	0	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	50	150	200	200			
84	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.03.21 (Yesterday)		14.03.21 (Today)		13.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	50	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	33	35	35	35	31		GT-9 Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	298	124	250	300				
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	75	80	86				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	205	143	150	160	88		Under maint.	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	18	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	6	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	341	341				
102	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	369	364	400	400				
103	Bibiyana South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	344	329	340	340				
	Shahjibazar	100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total						2416	2371	1953	1724	1953	2019	0	119	
104	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
105	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	350	425	400	400				
106	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
107	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna	115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	66	66	66				
110	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
111	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40				
112	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	70	70	90	90				
113	Machumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		722	722	734	734				
Khulna Zone Total						2288	2284	1142	1283	1565	1851	0	0	
114	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110				
115	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	25	33	33				
116	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.	
117	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	37	64	95	95				
118	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	520	620	620				
119	Potuaekhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
Bhola Nutan Biddut BD LTD						Gas/HSD	111	62	72	72				
Barishal Zone Total						1826	1826	520	703	1080	1080	0	194	
120	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
122		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
124		Ammura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	12	42	42	42				
125		Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	34	100	100				
126		Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
127		Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
128		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
129		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
130		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	154	185	200	200				
131		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	189	188	200	200				
132		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	425	400	400				
133		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	18	18				
134		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
135		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11				
136		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	52	52				
137		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	0	35	113	113				
138		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	35	113	113				
Rajshahi Zone Total						2193	2183	855	982	1549	1673	381	0	
139	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
141		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10			Under Overhauling	
142		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	70	109	113	113				
143		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144		Majpara, Talulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total						685	605	225	259	281	273	170	20	
Sub-total: Plants in operation						21778	21312	9212.0	9432	14421	15521	2541	1091	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								8678	8885	13584	14621			
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0			
Gross Total						21778	21312	9212	9432	14421	15521	2541	1091	
(C) Actual data of 13.03.21 (Yesterday) Saturday :														
01.	Max. Demand (Generation end)			: 9432.00 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):									
02.	Max. Demand (Sub-station end)			: 8885.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)			: 9432.00 MW, at = 21:00 hrs	Dhaka	3205	3205	0	Mymensingh	645	645	0		
04.	Minimum Generation (Generation end)			: 8017.00 MW, at = 5:00 hrs	Chattogram	1148	1148	0	Sylhet	285	285	0		
05.	Day-peak Generation (Generation end)			: 9212.00 MW, at = 12:00 hrs	Khulna	1112	1112	0	Barishal	270	270	0		
06.	Evening-peak Generation (Generation end)			: 9432.00 MW, at = 21:00 hrs	Rajshahi	884	884	0	Rangpur	544	544	0		
07.	Evening Peak Load-shed (Sub-station end)			: 0.00 MW, at = 21:00 hrs	Cumilla	792	792	0						
08.	Actual Minimum Generation Forecast up to 8:00			: 7189.00 MW, at = 5:00 hrs	Total 8885 8885 0									
09.	Generation shortfall at evening peak due to :				13. Fuel cost : (a) Gas = 149129594 Taka (c) Coal = 6533261 Taka									
	a) Gas limitation			: 2211 MW	(b) Oil = 217014867 Taka Total = 431477722 Taka									
	d) Coal supply Limitation			: 170 MW										
	b) Low water level in Kaptai lake			: 160 MW										
	c) Plants under shut down/ maintenance			: 1091 MW										
10.	Total Energy (Generation + India Import)			: 206.75 MKWh	14. Maximum Temperature in Dhaka was : 33.7° C									
	By Gas = 138.957 MKWh			31.462 MKWh	15. Export through East-West interconnections :									
	By Coal = 14.020 MKWh			By Hydro = 1.692 MKWh	At evening peak-hour : 300 MW, at 21:00 hrs									
	By Solar= 0.460 MKWh				Maximum : -50 MW, at 7:00 hrs									
11.	Total Gas Supplied			: 1114.10 MMCFD	Energy : 0.1395 MKWh									
(D) Forecast of 14.03.21 (Today) Sunday :														
01.	Maximum Demand			: 11800 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation			: 15521 MW (Generation end)	05. Total Generation : 258.65 MKWh									
03.	Maximum Shortage			: -3721 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 35.2° C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation