

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021		Day : Saturday				Date : 27.03.21					
Probable Maximum Demand :		12400 MW		Probable Maximum Generation :		19935 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 86.78 ft		Today = 86.54 ft		Rule Curve = 89.00 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	26.03.21 (Yesterday)		27.03.21 (Today)		26.03.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)	Evening	Probable Peak Generation (MW)	Evening			
(A) Plants in operation:											
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170		
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	190	190	190	190	175	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	87	95	99	99		
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hanpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	348	360	360	12	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	400	450	450		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	369	351	412	412	61	Gas Shortage
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	184	180	100	180		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	s/d for filter changing due to dirt in gas
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	50	100	100		
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	235	225	235	235	80	dirt in gas
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	30	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	85	85		
19	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	0	0	100	100		
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22		
21	Summit Power (Madhab+Ashula)	Gas (SIPP, REB)	6x8.7+7x8.73	80	80	40	54	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	28	28	33	33		
23	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	33	33	33	33		
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105		
26	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	16	82	149	149		
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	20	49	50	50		
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	60	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	122	149	149		
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300		
32	Bramhanon 100 MW PP (Aggregate)	HSD (IPP)	23x0.85+9x1x.959	100	100	0	0	50	100		
33	Aurahi 100MW PP (Aggregate)	HSD (IPP)	23x0.85+9x1x.959	100	100	0	0	100	100		
34	Nabaganj 55 MW PP (Southern part)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	70	104	104		
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	144	144		
	Spectra Solar Plant Ltd.	Solar (IPP)				32	0	30	0		
Dhaka Zone Total				6171	5972	2133	2770	4199	4499	508	745
39	Kamaghuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	8	25	25		
43	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	0	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	50	50		
45	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	0	0	50	100		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	120		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	204	225	225		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300		
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
50	Juldah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	102	102		
52	Hafhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	16	22	22		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			38	38	20	35		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	54	54		
56	Kamaghuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
58	Chattogram 116 MW PP (Arlima En)	HFO (IPP)	6x21.06	116	116	0	72	116	116		
Chattogram Zone Total				2442	2382	703	869	1679	1719	160	360
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	90	90	100	100	45	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26	19	Gas Shortage
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	199	181	225	225		
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	290	350	350		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	295	295	350	350		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	30	50	50		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	80	91	90	90	72	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	71	120	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	19	20	20		
76	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	89x1.4+69x1.57+15x1.08	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	41	75	113	113		
**	Impport (Tripura)	India		160	160	128	160	151	168		
	Bhairab 54.5 MW	HFO (IPP)				0	0	0	0		
Cumilla Zone Total				3040	2980	1395	1531	2095	2262	635	72
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	152	207	210	210		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	22	22		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.524	95	95	24	72	77	77		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	191	184	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0		
86	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	19	22	22	22		
Mymensingh Zone Total				717	709	526	617	698	646	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.03.21 (Yesterday)		27.03.21 (Today)		26.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance								
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date							
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)									
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	44	44	44										
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			GT-1 Load gear problem							
89	Fenchugonj 51 MW PP (Barakatula)	Gas (RPP)	19x2.90	51	51	50	53	51	51			GT-4 Shaft Problem							
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021							
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	140	163	163										
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0			66 Under maint.							
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	211	210	210	210										
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	80	81	81										
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	40	150	150	150			81 Water Problem							
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	18	20	20										
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020							
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	10	10										
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16										
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	310	341	341										
102	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	241	240	250	250			Gas Shortage							
103	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	310	310	400	400			73 Gas Shortage							
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0			On Test							
Sylhet Zone Total				2416	2371	1514	1619	1777	1777	160	233								
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16										
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	395	410	400	400			Gas Shortage							
106	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25										
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60										
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220										
109	Khulna 115 PP MW (KPLC 2)	HFO (QRPP)	7x17	115	115	83	99	99	99										
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	60	50	100										
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	8	33	40	40										
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	75	90	95										
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100										
**	Bheramara (HVDC)	India		1000	1000	727	720	735	735										
Khulna Zone Total				2288	2284	1213	1397	1599	1890	0	0								
114	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110										
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	26	25	25										
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	60	60	70	70			134 GT-2 & STG Under maint.							
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	13	13	95	95										
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	600	622	622										
119	Potlakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150										
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				175	124	120	120										
Barishal Zone Total				1826	1826	635	855	1192	1192	0	134								
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0			Gas Shortage							
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			Gas Shortage							
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50										
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200										
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40										
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42										
125	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100										
126	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50										
127	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50										
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	34										
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage							
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	201	198	200	200										
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	196	200	200										
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	409	388	400	400										
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	21	22	22										
134	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020							
135	Lillaipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
136	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	14	52	52	52										
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	95	95	113	113										
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113										
Rajshahi Zone Total				2193	2183	1041	1208	1643	1677	381	0								
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage							
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage							
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150			Coal Shortage							
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10										
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	97	113	113	113										
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
144	Majpara, Taula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0										
Rangpur Zone Total				685	605	253	263	281	273	294	0								
Sub-total: Plants in operation				21778	21312	9413.0	11129	15163	15935	2138	1544								
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						8855	10469	14263	14990										
(B) Contract expired power plants																			
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0								
Gross Total				21778	21312	9413	11129	15163	15935	2138	1544								
(C) Actual data of 26.03.21 (Yesterday) Friday :																			
01.	Max. Demand (Generation end)	:	11129.00 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :															
02.	Max. Demand (Sub-station end)	:	10469.00 MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed								
03.	Highest Generation (Generation end)	:	11129.00 MW, at = 21:00 hrs		MW	MW	MW		MW	MW	MW								
04.	Minimum Generation (Generation end)	:	8760.00 MW, at = 7:00 hrs	Dhaka	3606	3606	0	Mymensingh	970	970	0								
05.	Day-peak Generation (Generation end)	:	9413.00 MW, at = 12:00 hrs	Chattogram	916	916	0	Sylhet	407	407	0								
06.	Evening-peak Generation (Generation end)	:	11129.00 MW, at = 21:00 hrs	Khulna	1339	1339	0	Barishal	277	277	0								
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 21:00 hrs	Rajshahi	1188	1188	0	Rangpur	681	681	0								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8585.00 MW, at = 5:00 hrs	Cumilla	1085	1085	0												
09.	Generation shortfall at evening peak due to :	:		Total 10469 10469 0															
a)	Gas limitation	:	1684 MW	13. Fuel cost : (a) Gas = 155135594 Taka (c) Coal = 70195228 Taka (b) Oil = 342773212 Taka Total = 568104033 Taka															
d)	Coal supply Limitation	:	294 MW																
b)	Low water level in Kaplai lake	:	1640 MW																
c)	Plants under shut down/ maintenance	:	1544 MW																
10.	Total Energy (Generation + India Import)	:	234.88 MWh	14. Maximum Temperature in Dhaka was : 37.6° C															
	By Gas =	147.236 MWh	By Oil =	15. Export through East-West interconnections : At evening peak-hour : 30 MW, at 21:00 hrs Maximum : -200 MW, at 19:30 hrs Energy : 0.275 MWh															
	By Coal =	15.129 MWh	By Hydro =									1.700 MWh							
	By Solar =	0.704 MWh																	
11.	Total Gas Supplied	:	1186.25 MMCFD																
(D) Forecast of 27.03.21 (Today) Saturday :																			
01.	Maximum Demand	:	12400 MW (Generation end)	04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)												
02.	Maximum Generation	:	15935 MW (Generation end)	05.	Total Generation	:	261.70 MWh												
03.	Maximum Shortage	:	-3535 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	:	38.7° C												

*Captive Power ** Imported Power
 #Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Faouzul Islam Shaker)
 Deputy Secretary, Generation