

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021		Day : Sunday				Date : 28.03.21						
Probable Maximum Demand :		13000 MW				Probable Maximum Generation : 15725 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 86.54 ft				Today = 86.20 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.03.21 (Yesterday)		28.03.21 (Today)		27.03.21 Gen. shortfall for : Gas/water/Coal limitation MW	88.84 ft. Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	a) Ghorssel Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering	
1	b) Ghorssel Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
1	c) Ghorssel TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
2	Ghorssel 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	190	50	300	300	315	Gas Shortage	
3	Ghorssel 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	90	93	99	99			
4	Ghorssel 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Harpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Harpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	187	143	140	150	217	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	420	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	343	325	340	350	87	Gas Shortage	
11	Siddhirganj 2'120 MW GTTP	Gas (EGCB)	2 x 105	210	210	155	120	100	150			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	189	220	220	146	s/d for filter changing due to Dirt in gas	
13	Siddhirganj 100 PPI(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	30	100	100	100			
14	Meghnadhat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	225	235	235	235	70	dirt in gas	
15	Meghnadhat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	41	100	100	100			
16	Madanganj 102 PPI(Summit)	HFO (QRPP)	6x17	102	100	50	80	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	73	85	85			
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	24	102	100	100			
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
21	Summit Power,(Madhabdi+Ashulla)	Gas (SIPP, REB)	6x8.67+7x8.73	80	80	54	54	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
23	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	17	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	42	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	82	135	149	149			
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	102	275	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	120	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
32	Branhanganj 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	30	50	100			
33	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	54	100	100			
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
36	Bostila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
38	Manikganj 162MW PP(MPLG)	HFO (IPP)	9x18	162	162	76	144	144	144			
	Spectra Solar Plant Ltd.	Solar (IPP)				29	0	30	0			
Dhaka Zone Total				6171	5972	2884	3539	4237	4527	855	570	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x60	230	230	70	70	70	70	160	Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	44	50	50			
45	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	0	50	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	120			
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	190	188	225	225			
48	Anwara 300 MW PP (Unite)	HFO (IPP)	17x17.076+3x8.04	300	300	0	49	300	300			
49	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	100	100	100	100			
50	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	19	22	22			
*	Malancha, Ctg,EPZ (Unite)	Gas	5x8.73+3x9.34			2	12	10	15			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	78	90	90			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
58	Chattogram 116 MW PP (Anlima En	HFO (IPP)	6x21.06	116	116	38	116	116	116			
Chattogram Zone Total				2442	2382	875	1160	1652	1682	160	360	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	100	100	100	35	Gas Shortage	
59	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
59	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	118	80	80	80	54	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26	19	Gas Shortage	
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	30	213	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	265	350	350			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	310	260	350	350			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	44	30	50	50			
65	Ashuganj 195MW PP (APSCL-Unite)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	46	0	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	91	86	90	90	77	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	65	100	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	52	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	19	20	20			
76	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	86x1.4+8x1.510+1x1.06	200	200	0	30	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	99	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	106	113	113	113			
**	Impport (Tripura)	India		160	160	140	166	151	168			
	Bhairab 54.5 MW	HFO (IPP)				0	37	0	0			
Cumilla Zone Total				3040	2980	1476	1758	2095	2262	625	77	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	120	128	150	150			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	22	22			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	73	77	77			
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	174	183	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sulakhai											

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.03.21 (Yesterday)		28.03.21 (Today)		27.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	44	44			GT-1 Load gear problem
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			GT-4 Shaft Problem
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x2.90	51	51	53	50	51	51			
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163			
92	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0			66 Under maint.
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	135	137	150	150			193 STG under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	80	81	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	150	149	150	150			62 Water Problem
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	20	20			
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	7	10	10			
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	341	341			
102	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	241	241	250	250			159 Gas Shortage
103	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	310	311	0	0			72 Gas Shortage
	Shahjibazar 100 MW GTPP	Gas (PDB)				0	0	0	0			On Test
Sylhet Zone Total				2416	2371	1559	1513	1317	1317	159	428	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16			
105	Bheramara 410 MW CAPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	355	355	400	400			55 Gas Shortage
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	3	60	60			
108	Khulna 225 MW CAPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220			
109	Khulna 115 PP MW (KPCL 2)	HFO (QRPP)	7x17	115	115	83	66	99	99			
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100			
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	40	40			
112	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	70	75	90	95			
113	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100			
**	Bheramara (HVDC)	India		1000	1000	722	721	734	854			
Khulna Zone Total				2288	2284	1230	1353	1598	2009	55	0	
114	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	80	110	110			
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	33	25	25			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	60	50	70	70			144 GT-2 & STG Under maint.
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	23	75	95	95			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	550	622	622			
119	Potashali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150			
	Bhola Nutan Biddu BD LTD	Gas/HSD (IPP)				65	50	120	120			
Banshal Zone Total				1826	1826	584	838	1192	1192	0	144	
120	a) Baghabani 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage
	b) Baghabani 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	100			Gas Shortage
121	Baghabani 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50			
122	Baghabani 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	40	40			
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42			
125	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100			
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	50	50			
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	50	50			
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	34			
129	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	145	170	200			65 Gas Shortage
130	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	186	218	200	200			
131	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	187	180	200	200			
132	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	411	379	400	400			
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22			
134	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020
135	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11			
136	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	43	52	52	52			
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113			
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113			
Rajshahi Zone Total				2193	2183	1046	1482	1813	1877	236	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150			124 Coal Shortage
141	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	10	10			
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	98	113	113	113			
143	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Majpara, Tatula 8 MW Solar PP (Sympha Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
Rangpur Zone Total				685	605	254	263	281	273	294	0	
Sub-total: Plants in operation				21778	21312	10425.0	12446	14823	15725	2384	1579	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9933	11859	14124	14963			
(B) Contract expired power plants												
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0			
Gross Total				21778	21312	10425	12446	14823	15725	2384	1579	
(C) Actual data of 27.03.21 (Yesterday) Saturday :												
01.	Max. Demand (Generation end)	: 12446.00 MW, at = 19:30 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand (Sub-station end)	: 11859.00 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 12446.00 MW, at = 19:30 hrs	Dhaka	4299	4299	0	Mymensingh	1018	1018	0		
04.	Minimum Generation (Generation end)	: 8585.00 MW, at = 6:00 hrs	Chattoagram	1323	1323	0	Sylhet	428	428	0		
05.	Day-peak Generation (Generation end)	: 10425.00 MW, at = 12:00 hrs	Khulna	1412	1412	0	Barishal	316	316	0		
06.	Evening-peak Generation (Generation end)	: 12446.00 MW, at = 19:30 hrs	Rajshahi	1292	1292	0	Rangpur	780	780	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs	Cumilla	991	991	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9015.00 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
	a) Gas limitation	: 1930 MW	13. Fuel cost :		(a) Gas = 163655175 Taka	(c) Coal = 72898987 Taka						
	d) Coal supply Limitation	: 294 MW	(b) Oil = 411252761 Taka		Total = 647806923 Taka							
	b) Low water level in Kaptai lake	: 160 MW										
	c) Plants under shut down/ maintenance	: 1579 MW										
10.	Total Energy (Generation + India Import)	: 249.61 MKWh	14. Maximum Temperature in Dhaka was : 36.7° C									
	By Gas = 151.951 MKWh	By Oil = 58.628 MKWh	15. Export through East-West interconnections :									
	By Coal = 15.744 MKWh	By Hydro = 1.684 MKWh	At evening peak-hour : -55 MW, at 19:30 hrs									
	By Solar = 0.706 MKWh		Maximum : -120 MW, at 19:00 hrs									
11.	Total Gas Supplied	: 1242.40 MMCfD	Energy : 0.2555 MKWh									
(D) Forecast of 28.03.21 (Today) Sunday :												
01.	Maximum Demand	: 13000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 15725 MW (Generation end)	05.	Total Generation	: 260.72 MKWh							
03.	Maximum Shortage	: -2725 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 38.4° C							

* Captive Power ** Imported Power
#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation